

1600A, 25KA/3SEC, 20KV - BUS 1

CB 1250A, 25KA/3SEC

600-800/1A, CL5P20, 30VA

CT5 600-800/1A, CL0.2FS5, 30VA

PT $\frac{20}{\sqrt{3}} / \frac{0.11}{\sqrt{3}} / \frac{0.11}{\sqrt{3}}$ KV

CL 0.2+3p, 30VA

CL 0.2+3p, 30VA

ES 25KA/1SEC

NE

